



CITY OF WEST RICHLAND
PUBLIC WORKS DEPARTMENT
3801 W. VAN GIESEN
WEST RICHLAND, WA 99353
PHONE: (509)967-5434
FAX: (509)967-2419

DATE: February 20, 2013

TO: Suppliers and Contractors

FROM: Drew Woodruff, P.E., City Engineer 

SUBJECT: NEW LEAD REQUIREMENTS - NSF STANDARD 61

The City of West Richland will be enforcing the new NSF Standard 61 Lead leach limit. The change reduces allowable lead limit from 15 ppb to 5 ppb maximum for all NSF Standard 61 certified products. This maximum lead leach change applies to all wetted materials, including rubbers, plastics, adhesives, lubricants, etc. This change will be effective on any and all applicable material installed or delivered to the City as of April 1, 2013.