



**REDUCED PRESSURE BACKFLOW ASSEMBLY (RPBA)**

FOR ASSEMBLES 3/4" TO 1"

**NOTES**

1. MUST BE ON THE LATEST DEPT. OF HEALTH APPROVED LIST OF BACKFLOW PREVENTION ASSEMBLIES.
2. MUST BE INSTALLED ABOVE GROUND MIN. 12 INCHES.
3. A CITY OF WEST RICHLAND CROSS CONNECTION SPECIALIST MUST APPROVE CONNECTION.
4. WINTERIZING DCVA DEVICE AND IRRIGATION SYSTEM IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
5. NO BLOW-OFF ALLOWED BETWEEN CITY METER AND RPBA.
6. RPBA'S ANNUAL TESTING IS THE RESPONSIBILITY OF THE PROPERTY OWNER.

**REDUCED PRESSURE  
BACKFLOW ASSEMBLY**  
IRRIGATING W/ CITY AND IRRIGATION WATER



DESIGN:		SHEET: 1 OF 1
DRAWN: AFW		SCALE: N/A
CHECK: JL		DATE: 7/23/2009
APPR.:	CADFILE: RPBA-DCVA.DWG	