

## DOUBLE CHECK VALVE ASSEMBLY (DCVA)


FOR ASSEMBLIES 3/4" TO 1"

### NOTES

1. DCVA DEVICE MUST BE ON THE LATEST DEPT. OF HEALTH APPROVED LIST OF BACKFLOW PREVENTION ASSEMBLIES.
2. DCVA DEVICE MAY BE INSTALLED BELOW GROUND IN AN IRRIGATION BOX MEETING CLEARANCE REQUIREMENTS.
3. A CITY OF WEST RICHLAND CROSS CONNECTION SPECIALIST MUST INSPECT INSTALLATION BEFORE BURYING.
4. WINTERIZING DCVA DEVICE AND IRRIGATION SYSTEM IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
5. NO BLOW-OFF ALLOWED BETWEEN CITY METER AND DCVA.

# DOUBLE CHECK VALVE ASSEMBLY (DCVA) INSTALLATION

DESIGN:	
DRAWN: AFW	
CHECK: JL	
CADFILE: RPBA-DCVA.DWG	



SHEET: 1
SCALE: N/A
DATE: 7/23/2009