



PRESSURE VACUUM BREAKER ASSEMBLY (PVBA)

FOR ASSEMBLIES 3/4" TO 1"

NOTES

1. MUST BE ON THE LATEST DEPT. OF HEALTH APPROVED LIST OF BACKFLOW PREVENTION ASSEMBLIES.
2. MUST BE INSTALLED ABOVE GROUND BETWEEN 12" MIN AND 60" MAX ABOVE HIGHEST POINT IN THE SYSTEM.
3. SPRINKLER SYSTEM VALVES ARE ALLOWED DOWNSTREAM OF A PVBA.
4. A CITY OF WEST RICHLAND CROSS CONNECTION SPECIALIST MUST APPROVE CONNECTION.
5. SHALL ONLY BE USED ON SYSTEMS THAT ARE NOT SUBJECT TO BACK-PRESSURE. PVBA'S SHALL NEVER BE EXPOSED TO COMPRESSED AIR.
6. WINTERIZING PVBA DEVICE AND IRRIGATION SYSTEM IS THE RESPONSIBILITY OF THE PROPERTY OWNER.
7. NO BLOW-OFF ALLOWED BETWEEN CITY METER AND PVBA.
8. PVBA'S ANNUAL TESTING IS THE RESPONSIBILITY OF THE PROPERTY OWNER.

**PRESSURE VACUUM
BACKFLOW ASSEMBLY
INSTALLATION**



DESIGN:		SHEET: 1 OF 1
DRAWN: AFW		SCALE: N/A
CHECK: JL		DATE: 7/23/2009
APPR.:	CADFILE: RPBA-DCVA.DWG	